CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7315-1335:0106 Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: Altronix140 - 58th Street, Bldg A-3W, Brooklyn, NY 11220

Contact: Gary Zatz (718) 567-8181 Fax (718) 567-9056

Email: garyz@altronix.com

DESIGN: Models AL175UL, AL175ULX, AL400ULACM, AL400ULACMCB, AL600ULACM,

AL600ULACMCB, ACM8E and ACM8CBE power supply units. Units are intended for use in application with access control systems. Refer to listee's data sheet for additional detailed

product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply unit accessory for use for general purpose or access control

systems. Not suitable for fire alarm control units.

Rev. 01-30-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2020 Listing Expires June 30, 2021

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division