



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	3774-0923:0101
<b>CATEGORY:</b>	3774 - ELECTRIC LOCKS
<b>LISTEE:</b>	Securitron Magnalock 10027 S. 51st St., Ste. 102, Phoenix, AZ, 85044 Contact: Peabody, Josh 6235824626 Email: josh.peabody@assaabloy.com
<b>DESIGN:</b>	Models Series 32, 34, 38, 62, 68, 82 SAM and SAM2 exit locks with suffix -C, -DV, -S, -L, -F or -G. Unit consists of a lock assembly, door mounting hardware and means for connecting to a remote control circuit. Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	12 or 24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as electromagnetic locks for use on *rated door assemblies up to one-hour or non-rated door assemblies to prevent unauthorized entry when the building is unoccupied. Authority having jurisdiction shall be consulted prior to installation.
<b>NOTES:</b>	

\*Rev. 08-18-11 mt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/14/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division